

SOFTBALL DIAMOND LAYOUT W/ BACKSTOP (TYPE "A") AND ACCESSIBLE DUGOUT

Scale: 1" = 20'



BASEBALL DIAMOND LAYOUT W/ BACKSTOP (TYPE "A") AND ACCESSIBLE DUGOUT

Scale: 1" = 20'

ACCESSIBILITY DESIGN GUIDELINES

1. Cross slope of accessible routes including connections to the playing field shall not exceed 1:50. Direction of cross slope shall generally follow the drainage pattern of the field.
2. Running slope of accessible routes including connections to the playing field shall not exceed 1:20.
3. Slope of concrete pads for accessible dugout and bleachers shall not exceed 1:50 in any direction.
4. All joints and connections along the accessible route shall be smooth and flush.
5. All joints and connections at thresholds, curbs and transitions for all passages including gates shall be smooth and flush.
6. Bleachers if applicable shall comply with ADAAG 4.1.3 (19) and shall be located along an accessible route.

Accessible Softball/Baseball Layout appears to meet ADAAG as required by HRS 103-50 per Disability and Communication Access Board Document Review, February 23, 2000, DCAB Job # 2000-277

CITY COUNTY OF HONOLULU	SOFTBALL/BASEBALL DIAMOND LAYOUTS W/TYPE "A" BACKSTOP AND ACCESS DUGOUTS SCALE: 1"=20' REVISED: MARCH 2006	STANDARD DETAILS	B-13