

Revised August 1, 2012

MAKE, MODEL, AND SIZE OF METERS
APPROVED BY BOARD OF WATER SUPPLY

I. DISPLACEMENT METER

<u>Manufacturer</u>	<u>Model</u>	<u>Size</u>
Sensus Metering System	Int'l SR	5/8" x 3/4", 3/4", 1", 1-1/2", 2"
Sensus Metering System	SR II	5/8" x 3/4", 3/4" x 3/4", 1" x 1"
Neptune Technology Group	T-10	5/8" x 3/4", 3/4" x 3/4", 1" x 1", 1-1/2", 2"

II. COMPOUND METER

Neptune Technology Group	Tru/Flo	3", 4", 6"
Sensus Metering System	Omni C2	3", 4", 6"

III. DETECTOR CHECK METER

Hersey Meter Co.	DC-LA-EDC-III	4", 6", 8"
------------------	---------------	------------

IV. TURBINE METER

Sensus Metering System	Omni T2	2", 3", 4", 6", 8"
Sensus Metering System	W-3500 DR	8"
Neptune Technology Group	HP Turbine	2", 3", 4", 6", 8"

V. FIRE HYDRANT METER

Sensus Metering System	125W	3"
------------------------	------	----

VI. FIRE SERVICE METER

Sensus Metering System	Fireline Fire Service (FM)	4", 6", 8"
Sensus Metering System	Omni F2	4", 6", 8"
Neptune Technology Group	HP Protectus III	4", 6", 8"

SUBMETER NEEDS TO MEASURE IN
"GALLONS" AND NOT IN CUBIC FEET.