


DEPARTMENT OF ENVIRONMENTAL SERVICES  
**CITY AND COUNTY OF HONOLULU**

1000 ULUOHIA STREET, SUITE 308, KAPOLEI, HAWAII 96707  
TELEPHONE: (808) 768-3486 • FAX: (808) 768-3487 • WEBSITE: <http://www.co.honolulu.gov>

MUFI HANNEMANN  
MAYOR



TIMOTHY E. STEINBERGER, P.E.  
DIRECTOR

MANUEL S. LANUEVO, P.E., LEED AP  
DEPUTY DIRECTOR

ROSS S. TANIMOTO, P.E.  
DEPUTY DIRECTOR

IN REPLY REFER TO:  
PRO 09-019

March 11, 2009

TO: ARCHITECTS AND ENGINEERS

FROM:  TIMOTHY E. STEINBERGER, P.E., DIRECTOR  
DEPARTMENT OF ENVIRONMENTAL SERVICES

SUBJECT: ENGINEERING AND POLICY MEMORANDUM

Effective immediately, the following sections contained within the Design Standards of the Department of Wastewater Management, Volume 1, dated July 1993 are suspended:

Section 36.1 (Overflow)  
Section 38.7.3 (Emergency By-Pass)  
Section 38.7.4

The purpose of this suspension is that engineered overflow pipes and emergency by-passes that are designed for the purpose of discharging untreated wastewater from any part of our gravity collection system, from a pump station or from a force main to the environment is not allowed. Should there be any questions, please contact Jack Pobuk, Program Coordinator, at 768-3464.